

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



2 of 2

General Comments

Satisfactory at time of inspection. Escorted through facility.

Email Address(es): gkey@pasco.k12.fl.us;
jlopez@pasco.k12.fl.us;
bburgess@pasco.k12.fl.us

Violations Comments

Violation #5. Maintenance & Repair

Observed several ceiling tiles with water marks in building 12. Ensure that leaks have been repaired and replace ceiling tiles as needed. Replace ceiling tiles as needed throughout campus.

CODE REFERENCE: 5. Maintenance and Repair. 5(1)(e)8.h SREF. Light fixtures and window surfaces, both inside and outside, shall be kept clean, serviceable, and in good repair at all times. 5(1)(e)8.i. Custodial areas shall be kept clean, safe, and orderly at all times. Custodial equipment shall be in good repair at all times. 5(1)(e)8.j SREF. Building components & finishes shall be kept clean & in good repair.

Violation #6. Lighting Standards

Observed busted light shield in restroom 12-123. Replace light shield in that restroom.

CODE REFERENCE: 6. Lighting Standards. 468.3.2. FBC. Sources of natural light in instructional spaces shall be glazed with glare reducing materials or shall be shielded to prevent glare that can interfere with seeing task.

Inspection Conducted By: Alicia Steiert (85862)
Inspector Contact Number: Work: (352) 521-1450 ex. 6164
Print Client Name:
Date: 1/30/2019

Inspector Signature:

A Steiert

Client Signature:

King King