

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



1 of 2

Facility Information

RESULT: Satisfactory

Permit Number: 51-51-01998
Name of Facility: Double Branch Elementary School
Address: 31500 Chancey Road
City, Zip: Wesley Chapel 33543

Correct By: None
Re-Inspection Date: None

Type: Public Schools
Owner: Pasco County School Board
Person In Charge: Cherryl Morris Phone: (813) 794-2443
PIC Email: cmorris@pasco.k12.fl.us

Inspection Information

Purpose: Routine
Inspection Date: 2/8/2019

Begin Time: 09:25 AM
End Time: 10:00 AM

Additional Information

FEMALES 360 CENSUS 720
MALES 360

This form serves as a "Notice of Non-Compliance" pursuant to section 120.695, Florida Statutes. Items marked below violate one or more of the requirements of Rule 6A-2.0010, of the Florida Administrative Code, Chapter 5, section 5 of the State Requirements for Educational Facilities 2014 (SREF); and sections 453 and 468 of the Florida Building Code 6th Edition (2017). Violations must be corrected within the time period indicated above. Continued operation of this facility without making these corrections is a violation. Failure to correct violations in the time frame specified may result in enforcement action being initiated by the Department of Health.

Violation Markings

SCHOOL SANITATION		
<u>IN</u> 1. School Site	<u>IN</u> 11. Group Toilet Rooms	<u>IN</u> 21. Pest Control
<u>IN</u> 2. Playground, Equip & Athletic Fields*	<u>IN</u> 12. Toilet Facilities	SAFETY
<u>IN</u> 3. Athletic & Playground Equipment	<u>IN</u> 13. Handwashing Facilities	<u>IN</u> 22. First Aid Kit
BUILDING CONST/MAINT.	<u>IN</u> 14. Soap Dispensers	DIAPER CHANGING STATION
<u>IN</u> 4. Construction	<u>NA</u> 15. Shower Facilities	<u>NA</u> 23. Sanitizers
<u>IN</u> 5. Maintenance & Repair	<u>NA</u> 16. Showers Water Temperatures	<u>NA</u> 24. Changing Station & Mats
<u>IN</u> 6. Lighting Standards	WATER SUPPLY	<u>NA</u> 25. Hand Sink
<u>IN</u> 7. Heating, Ventilation, A/C Standards	<u>IN</u> 17. Approved Source	<u>NA</u> 26. Garbage Can
<u>IN</u> 8. Natural Ventilation	<u>IN</u> 18. Drinking Fountains	ANIMAL HEALTH & SAFETY
<u>IN</u> 9. Mechanical Ventilation	LIQUID WASTE & WASTE WATER	<u>NA</u> 27. Animal Maintenance/Aggressive
SANITARY FACILITIES	<u>IN</u> 19. Sewage Disposal	DORM/RESIDENTIAL FACILITIES
<u>IN</u> 10. Provided/Accessible/Separation	<u>IN</u> 20. Solid Waste	<u>NA</u> 28. Maintenance/Complaint
	PEST CONTROL	<u>NA</u> 29. Other

Marking Key: *IN = the act or item was observed to meet standards; OUT = the act or item was observed not to meet standards; NO = the act or item was not observed to be occurring at the time of inspection; NA = the act or item is not performed by the facility or not part of the operation*

Violation Key: * = 2. Playground, Equipment & Athletic Fields

General Comments

Satisfactory at time of inspection.
Escorted throughout facility.

Email Address(es): cmorris@pasco.k12.fl.us

Inspector Signature:

Client Signature:

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



2 of 2

Violations Comments

No Violation Comments Available

Inspection Conducted By: Alicia Steiert (85862)
Inspector Contact Number: Work: (352) 521-1450 ex. 6164
Print Client Name:
Date: 2/8/2019

Inspector Signature:

Alicia Steiert

Client Signature:

Lindy